

2025 Consumer Confidence Report Data

WEST SALEM WATERWORKS, PWS ID: 63203349

Water System Information

If you would like to know more about the information contained in this report, please contact Lee Schwier at (608) 786-2850.

Opportunity for input on decisions affecting your water quality

The Village of West Salem board meetings are held each month on the first and third Tuesday at 7:00 PM in the Community Center meeting room 175 Leonard St South

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source ID	Source	Depth (in feet)	Status
2	Groundwater	520	Active
3	Groundwater	453	Active
4	Groundwater	392	Active

To obtain a summary of the source water assessment please contact, Lee Schwier at (608) 786-2850.

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
HA and HAL	HA: Health Advisory. An estimate of acceptable drinking water levels for a chemical substance based on health effects information. HAL: Health Advisory Level is a concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice. Health Advisories are determined by US EPA.
HI	HI: Hazard Index: A Hazard Index is used to assess the potential health impacts associated with mixtures of contaminants. Hazard Index guidance for a class of contaminants or mixture of contaminants may be determined by the US EPA or

Term	Definition
	Wisconsin Department of Health Services. If a Health Index is exceeded a system may be required to post a public notice.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
PHGS	PHGS: Public Health Groundwater Standards are found in NR 140 Groundwater Quality. The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.
RPHGS	RPHGS: Recommended Public Health Groundwater Standards: Groundwater standards proposed by the Wisconsin Department of Health Services. The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.
SMCL	Secondary drinking water standards or Secondary Maximum Contaminant Levels for contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.
TCR	Total Coliform Rule

Term	Definition
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2025)	Violation	Typical Source of Contaminant
HAA5 (ppb)	D-46	60	60	39	39		No	By-product of drinking water chlorination
TTHM (ppb)	D-46	80	0	6.7	6.7		No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2025)	Violation	Typical Source of Contaminant
BARIUM (ppm)		2	2	0.018	0.010 - 0.018	2/16/2023	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	0.6	0.4 - 0.6	2/9/2023	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2025)	Violation	Typical Source of Contaminant
								from fertilizer and aluminum factories
MERCURY (ppb)		2	2	0.1	0.0 - 0.1	2/23/2023	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
SELENIUM (ppb)		50	50	1	0 - 1	2/23/2023	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
SODIUM (ppm)		n/a	n/a	6.31	3.46 - 6.31	2/23/2023	No	n/a

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	Range	# of Results	Sample Date (if prior to 2025)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.1190	0.0000 - 0.1680	0 of 20 results were above the action level.	7/23/2023	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	1.34	0.00 - 3.62	0 of 20 results were above the	7/12/2023	No	Corrosion of household plumbing systems; Erosion of

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	Range	# of Results	Sample Date (if prior to 2025)	Violation	Typical Source of Contaminant
					action level.			natural deposits

Radioactive Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2025)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)		15	0	2.9	-0.4 - 2.9	2/23/2023	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)		5	0	1.2	1.0 - 1.2	2/23/2023	No	Erosion of natural deposits
GROSS ALPHA, INCL. R & U (n/a)		n/a	n/a	2.9	-0.4 - 2.9	2/23/2023	No	Erosion of natural deposits

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA required us to participate in this monitoring.

Within the last 12 months we conducted Unregulated Contaminant Monitoring in accordance with US EPA rules. We are required to inform you of this sampling. We are only required to include results showing detections within this report; however, if you would like a copy of all results, please contact us at (608) 786-2850.

WI6320334	WEST SALEM WATERWORKS	4:2 FTS	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533 S GW	EP	Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	4:2 FTS	< MRL	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533 S GW	EP	Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	6:2 FTS	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533 S GW	EP	Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	6:2 FTS	< MRL	5/21/2024

00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	8:2 FTS	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	8:2 FTS	< MRL	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	9Cl-PF3ONS	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	9Cl-PF3ONS	< MRL	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	11Cl-PF3OUdS	< MRL	
5/21/2024	00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2
POE SE1	117015P	EPA 533	S	GW EP Region 5
WI6320334	WEST SALEM WATERWORKS	11Cl-PF3OUdS	< MRL	
5/21/2024	00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4
POE SE1	117017P	EPA 533	S	GW EP Region 5
WI6320334	WEST SALEM WATERWORKS	ADONA	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	ADONA	< MRL	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	HFPO-DA	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	HFPO-DA	< MRL	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	lithium	< MRL10	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 200.7	S	GW EP Region 5	WI N
WI6320334	WEST SALEM WATERWORKS	lithium	< MRL10	5/21/2024
00003T	Well 3 (BG177)	3	Finished Water Tap - Well 3 POE	SE1
117016P	EPA 200.7	S	GW EP Region 5	WI N
WI6320334	WEST SALEM WATERWORKS	lithium	< MRL10	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 200.7	S	GW EP Region 5	WI N
WI6320334	WEST SALEM WATERWORKS	NEtFOSAA	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 537.1	S	GW EP Region 5	WI N/A
WI6320334	WEST SALEM WATERWORKS	NEtFOSAA	< MRL	5/21/2024
00003T	Well 3 (BG177)	3	Finished Water Tap - Well 3 POE	SE1
117016P	EPA 537.1	S	GW EP Region 5	WI N

00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533 S	GW	EP Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	PFHpA	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533 S	GW	EP Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	PFHpA	< MRL	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533 S	GW	EP Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	PFHpS	< MRL	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533 S	GW	EP Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	PFHpS	< MRL	5/21/2024
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533 S	GW	EP Region 5 WI	N/A
WI6320334	WEST SALEM WATERWORKS	PFHxA	< MRL3	5/21/2024
00002T	Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1
117015P	EPA 533 S	GW	EP Region 5 WI	N WI6320334
WEST SALEM WATERWORKS	PFHxA	< MRL3	5/21/2024	
00004T	Well 4 (KW459)	4	Finished Water Tap - Well 4 POE	SE1
117017P	EPA 533 S	GW	EP Region 5 WI	N WI6320334
WEST SALEM WATERWORKS	PFHxS	< MRL	5/21/2024	00002T
Well 2 (TU521)	2	Finished Water Tap - Well 2 POE	SE1	117015P
EPA 533 S	GW	EP	Region 5 WI	N/A WI6320334
WEST SALEM WATERWORKS	PFHxS	< MRL	5/21/2024	00004T
(KW459)	4	Finished Water Tap - Well 4 POE	SE1	117017P
S	GW	EP	Region 5 WI	N/A WI6320334
WEST SALEM WATERWORKS	PFMBA	< MRL	5/21/2024	00002T
(TU521)	2	Finished Water Tap - Well 2 POE	SE1	117015P
S	GW	EP	Region 5 WI	N/A WI6320334
WEST SALEM WATERWORKS	PFMBA	< MRL	5/21/2024	00004T
(KW459)	4	Finished Water Tap - Well 4 POE	SE1	117017P
S	GW	EP	Region 5 WI	N/A WI6320334
WEST SALEM WATERWORKS	PFMPA	< MRL	5/21/2024	00002T
(TU521)	2	Finished Water Tap - Well 2 POE	SE1	117015P
S	GW	EP	Region 5 WI	N/A WI6320334
WEST SALEM WATERWORKS	PFMPA	< MRL	5/21/2024	00004T
(KW459)	4	Finished Water Tap - Well 4 POE	SE1	117017P
S	GW	EP	Region 5 WI	N/A WI6320334
WEST SALEM WATERWORKS	PFNA	< MRL	5/21/2024	00002T
2	Finished Water Tap - Well 2 POE	SE1	117015P	EPA 533 S
GW	EP	Region 5 WI	N/A WI6320334	WEST SALEM
WEST SALEM WATERWORKS	PFNA	< MRL	5/21/2024	00004T
4	Finished Water Tap - Well 4 POE	SE1	117017P	EPA 533 S
GW	EP	Region 5 WI	N/A WI6320334	WEST SALEM
WEST SALEM WATERWORKS	PFOA	< MRL	5/21/2024	00002T
2	Finished Water Tap - Well 2 POE	SE1	117015P	EPA 533 S

	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFOA < MRL		5/21/2024	00004T	Well 4 (KW459)	
	4		Finished Water Tap - Well 4	POE	SE1	117017P	EPA 533	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFOS < MRL		5/21/2024	00002T	Well 2 (TU521)	
	2		Finished Water Tap - Well 2	POE	SE1	117015P	EPA 533	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFOS < MRL		5/21/2024	00004T	Well 4 (KW459)	
	4		Finished Water Tap - Well 4	POE	SE1	117017P	EPA 533	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFPeA < MRL		5/21/2024	00002T	Well 2 (TU521)	
	2		Finished Water Tap - Well 2	POE	SE1	117015P	EPA 533	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFPeA < MRL		5/21/2024	00004T	Well 4 (KW459)	
	4		Finished Water Tap - Well 4	POE	SE1	117017P	EPA 533	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFPeS < MRL		5/21/2024	00002T	Well 2 (TU521)	
	2		Finished Water Tap - Well 2	POE	SE1	117015P	EPA 533	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFPeS < MRL		5/21/2024	00004T	Well 4 (KW459)	
	4		Finished Water Tap - Well 4	POE	SE1	117017P	EPA 533	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFTA < MRL		5/21/2024	00002T	Well 2 (TU521)	
	2		Finished Water Tap - Well 2	POE	SE1	117015P	EPA 537.1	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFTA < MRL		5/21/2024	00003T	Well 3 (BG177)	
	3		Finished Water Tap - Well 3	POE	SE1	117016P	EPA 537.1	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFTA < MRL		5/21/2024	00004T	Well 4 (KW459)	
	4		Finished Water Tap - Well 4	POE	SE1	117017P	EPA 537.1	S
	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFTTrDA < MRL		5/21/2024	00002T	Well 2	
(TU521)	2		Finished Water Tap - Well 2	POE	SE1	117015P	EPA 537.1	
S	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFTTrDA < MRL		5/21/2024	00003T	Well 3	
(BG177)	3		Finished Water Tap - Well 3	POE	SE1	117016P	EPA 537.1	
S	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFTTrDA < MRL		5/21/2024	00004T	Well 4	
(KW459)	4		Finished Water Tap - Well 4	POE	SE1	117017P	EPA 537.1	
S	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFUUnA < MRL		5/21/2024	00002T	Well 2	
(TU521)	2		Finished Water Tap - Well 2	POE	SE1	117015P	EPA 533	
S	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	
WATERWORKS			PFUUnA < MRL		5/21/2024	00004T	Well 4	
(KW459)	4		Finished Water Tap - Well 4	POE	SE1	117017P	EPA 533	
S	GW	EP	Region 5	WI	N/A	WI6320334	WEST SALEM	

WATERWORKS	4:2 FTS	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	6:2 FTS	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	8:2 FTS	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	9Cl-PF3ONS	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	11Cl-PF3OUdS	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	ADONA	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	HFPO-DA	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	NFDHA	< MRL	7/17/2024	00003T	Well 3
(BG177)	3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533
S	GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM
WATERWORKS	PFBA	< MRL	7/17/2024	00003T	Well 3 (BG177)
3	Finished Water Tap - Well 3	POE SE1	119280R	EPA 533	S
GW	EP	Region 5	WI	N/A WI6320334 WEST SALEM	WATERWORKS
PFBS	< MRL	7/17/2024	00003T	Well 3 (BG177)	3
Finished Water Tap - Well 3	POE SE1	119280R	EPA 533	S	GW
EP	Region 5	WI	N/A WI6320334	WEST SALEM	WATERWORKS
PFDA	< MRL	7/17/2024	00003T	Well 3 (BG177)	3
Finished Water Tap - Well 3	POE SE1	119280R	EPA 533	S	GW
EP	Region 5	WI	N/A WI6320334	WEST SALEM	WATERWORKS
PFDoA	< MRL	7/17/2024	00003T	Well 3 (BG177)	3
Finished Water Tap - Well 3	POE SE1	119280R	EPA 533	S	GW
EP	Region 5	WI	N/A WI6320334	WEST SALEM	WATERWORKS
PFEESA	< MRL	7/17/2024	00003T	Well 3 (BG177)	3
Finished Water Tap - Well 3	POE SE1	119280R	EPA 533	S	GW
EP	Region 5	WI	N/A WI6320334	WEST SALEM	WATERWORKS
PFHpA	< MRL	7/17/2024	00003T	Well 3 (BG177)	3
Finished Water Tap - Well 3	POE SE1	119280R	EPA 533	S	GW
EP	Region 5	WI	N/A WI6320334	WEST SALEM	WATERWORKS
PFHpS	< MRL	7/17/2024	00003T	Well 3 (BG177)	3
Finished Water Tap - Well 3	POE SE1	119280R	EPA 533	S	GW
EP	Region 5	WI	N/A WI6320334	WEST SALEM	WATERWORKS
PFHxA	< MRL	7/17/2024	00003T	Well 3 (BG177)	3

Finished Water Tap - Well 3 POE	SE1	119280R	EPA 533	S	GW	EP	Region 5	WI	N/A
< MRL	7/17/2024	00003T	Well 3 (BG177)	3	Finished				
Water Tap - Well 3 POE	SE1	119280R	EPA 533	S	GW	EP	Region		
5	WI	N/A	WI6320334	WEST SALEM WATERWORKS	PFMBA	< MRL			
7/17/2024	00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3				
POE	SE1	119280R	EPA 533	S	GW	EP	Region 5	WI	N/A
WI6320334	WEST SALEM WATERWORKS	PFMPA	< MRL	7/17/2024					
00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3 POE	SE1				
119280R	EPA 533	S	GW	EP	Region 5	WI	N/A		
WI6320334	WEST SALEM WATERWORKS	PFNA	< MRL	7/17/2024					
00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3 POE	SE1				
119280R	EPA 533	S	GW	EP	Region 5	WI	N/A		
WI6320334	WEST SALEM WATERWORKS	PFOA	< MRL	7/17/2024					
00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3 POE	SE1				
119280R	EPA 533	S	GW	EP	Region 5	WI	N/A		
WI6320334	WEST SALEM WATERWORKS	PFOS	< MRL	7/17/2024					
00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3 POE	SE1				
119280R	EPA 533	S	GW	EP	Region 5	WI	N/A		
WI6320334	WEST SALEM WATERWORKS	PFPeA	< MRL	7/17/2024					
00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3 POE	SE1				
119280R	EPA 533	S	GW	EP	Region 5	WI	N/A		
WI6320334	WEST SALEM WATERWORKS	PFPeS	< MRL	7/17/2024					
00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3 POE	SE1				
119280R	EPA 533	S	GW	EP	Region 5	WI	N/A		
WI6320334	WEST SALEM WATERWORKS	PFUnA	< MRL	7/17/2024					
00003T	Well 3 (BG177)	3	Finished	Water Tap - Well 3 POE	SE1				
119280R	EPA 533	S	GW	EP	Region 5	WI	N/A		

Additional Health Information

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. West Salem Waterworks is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact West Salem Waterworks (Lee Schwier at (608) 786-2850). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Information on Service Line Materials

We developed an inventory of service lines connected to our distribution system. You can access the inventory by following these instructions: Available on the Village of West Salem Website: <https://westsalemwi.gov/> Also available upon request at Village Hall 175 Leonards St. South